

CITY OF CORRY MUNICIPAL AUTHORITY

PWSID #: 6250012

2017 ANNUAL DRINKING WATER QUALITY REPORT

Este informe contiene información importante acerca de su agua potable. Haga que alguien lo traduzca para usted, ó hable con alguien que lo entienda. (This report contains important information about your drinking water. Have someone translate it for you, or speak with someone who understands it.)

WATER SYSTEM INFORMATION:

This report shows our water quality and what it means. If you have any questions about this report or concerning your water utility, please contact Jason Biondi at 814-663-7041.

SOURCE(S) OF WATER:

Our ground water source is 7 wells. These wells are located in the city's well field north of the City of Corry on Sciota Road.

A *Source Water Assessment* of our water source was completed by the PA Department of Environmental Protection (PA DEP). The Assessment has found that our water source is potentially most susceptible to road deicing material, accidental spills along roads, and materials associated with agricultural use. Overall, our source has little risk of significant contamination. A summary report of the Assessment is available by writing to the City of Corry Water Department at 100 S. Center St, Corry, PA 16407. It is also available on the *Source Water Assessment & Protection Web page* at (<http://www.dep.state.pa.us/dep/deputate/watermgmt/wc/Subjects/SrceProt/SourceAssessment/default.htm>). Complete reports were distributed to municipalities, water supplier, local planning agencies and PA DEP offices. Copies of the complete report are available for review at the PA DEP NW Regional Office, 230 Chestnut St., Meadville, PA 16335, Records Management Unit at (814) 332-6899.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the *Safe Drinking Water Hotline* (800-426-4791).

MONITORING YOUR WATER:

We routinely monitor for contaminants in your drinking water according to federal and state laws. The following tables show the results of our monitoring for the period of January 1 to December 31, 2017. The State allows us to monitor for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data is from prior years in accordance with the Safe Drinking Water Act. The date has been noted on the sampling results table.

DEFINITIONS:

Action Level (AL) - The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Minimum Residual Disinfectant Level (MinRDL) - The minimum level of residual disinfectant required at the entry point to the distribution system.

Treatment Technique (TT) - A required process intended to reduce the level of a contaminant in drinking water.

Mrem/year = millirems per year (a measure of radiation absorbed by the body)

pCi/L = picocuries per liter (a measure of radioactivity)

ppb = parts per billion, or micrograms per liter ($\mu\text{g/L}$)

ppm = parts per million, or milligrams per liter (mg/L)

ppq = parts per quadrillion, or picograms per liter

ppt = parts per trillion, or nanograms per liter

DETECTED SAMPLE RESULTS:

| Chemical Contaminants | | | | | | | | |
|---------------------------------|------------------|------|----------------|---------------------|-------|-------------|---------------|---|
| Contaminant | MCL in CCR Units | MCLG | Level Detected | Range of Detections | Units | Sample Date | Violation Y/N | Sources of Contamination |
| Chlorine – Highest Monthly Avg. | 4 | 4 | 0.68 | 0.40-0.68 | ppm | 06/13/17 | N | Water additive used to control microbes |
| Nitrate | 10 | 10 | 0.78 | 0.78 | ppm | 07/11/17 | N | Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits |
| Nitrite | 1 | 1 | 0.00 | 0.00 | ppm | 07/11/17 | N | Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits |
| Total Trihalo-methanes | 80 | 80 | 17.1 | 8.92-17.1 | ppb | 08/14/17 | N | By-product of drinking water chlorination |
| Haloacetic Acids | 60 | 60 | 3.53 | 2.34-3.53 | ppb | 08/14/17 | N | By-product of drinking water chlorination |

| Entry Point Disinfectant Residual | | | | | | | |
|--|-------------------------------|-----------------------|---------------------|-------|-------------|---------------|--|
| Contaminant | Minimum Disinfectant Residual | Lowest Level Detected | Range of Detections | Units | Sample Date | Violation Y/N | Sources of Contamination |
| Chlorine | 0.40 | 0.0 | 0.0 – 0.68 | ppm | 02/07/17 | N | Water additive used to control microbes. |

| Microbial | | | | | |
|---|--|------|------------------------------------|---------------|---------------------------------------|
| Contaminants | MCL | MCLG | Highest # or % of Positive Samples | Violation Y/N | Sources of Contamination |
| Total Coliform Bacteria | For systems that collect <40 samples/month: • More than 1 positive monthly sample | 0 | 0 | N | Naturally present in the environment. |
| Fecal Coliform Bacteria or <i>E. coli</i> | 0 | 0 | 0 | N | Human and animal fecal waste. |

OTHER VIOLATIONS: Tier II notice was sent out as required in 2015 related to the equipment malfunction the City of Corry Water Dept experienced in Jan 2015 that resulted in a lack of documentation of adequate chlorination for more than 4 hours. Water quality was never compromised and public health was never endangered.

HEALTH EFFECTS:

Information about Total Coliform Bacteria - Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other potentially-harmful, bacteria may be present. Coliforms were found in more samples than allowed and this was a warning of potential problems.

EDUCATIONAL INFORMATION:

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban stormwater run-off, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA and DEP prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA and DEP regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's *Safe Drinking Water Hotline* (800-426-4791).

Information about Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The City of Corry is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

OTHER INFORMATION

Thank you for allowing us to continue providing your family with clean, quality water this year. We ask that all of our customers actively help us protect and conserve our water sources. In order to maintain a safe and dependable water supply we sometimes need to make improvements to our system that will benefit all of our customers. These improvements may at times be reflected as a rate increase to you, the customer. Thank you for your understanding. Please call our office at 663-7041 if you have any questions.